


TYPICAL PAVED ROAD CROSSING WITH JACK AND BORE DETAIL Not to Scale





Point Name	Span Reference	Easting(NAD83)	Northing(NAD83)	Longitude	Latitude	Description	Length	Estimated Depth	<b>Estimated Bore Conduit</b>
ROAD001	Circuit 1, Circuit 2, Circuit 3, Circuit 4	457466.5453'	1479824.5135'	W074° 37' 45.65"	N042° 53' 43.13"	Clinton Rd.	80 FT	60 IN	8 IN SCH 80 HDPE
ROAD002	Circuit 2	453946.9225'	1485905.4584'	W074° 38' 33.08"	N042° 54' 43.14"	Moyer Dr.	50 FT	60 IN	8 IN SCH 80 HDPE
ROAD003	Circuit 3, Circuit 4	454341.4124'	1481300.5345'	W074° 38' 27.67"	N042° 53' 57.66"	Nestle Rd.	50 FT	60 IN	8 IN SCH 80 HDPE
ROAD004	Circuit 3	453455.1508'	1482398.2699'	W074° 38' 39.6"	N042° 54' 08.49"	Nestle Rd.	50 FT	60 IN	8 IN SCH 80 HDPE
ROAD005	Circuit 3, Circuit 4	451204.0302'	1479181.3107'	W074° 39' 09.77"	N042° 53' 36.67"	Marshville Rd.	80 FT	60 IN	8 IN SCH 80 HDPE
ROAD006	Circuit 4	453933.0609'	1470871.0307'	W074° 38' 32.92"	N042° 52' 14.63"	Dygert Rd.	60 FT	60 IN	8 IN SCH 80 HDPE
ROAD007	Circuit 4	456466.1028'	1474015.1513'	W074° 37' 58.97"	N042° 52' 45.73"	G Bowerman Rd.	80 FT	60 IN	8 IN SCH 80 HDPE
ROAD008	Circuit 4	458800.4545'	1472911.15'	W074° 37' 27.59"	N042° 52' 34.86"	Marshville Rd.	80 FT	60 IN	8 IN SCH 80 HDPE
ROAD009	Circuit 3	451064.6007'	1479593.7957'	W074° 39' 11.66"	N042° 53' 40.74"	Dunckel Rd.	60 FT	60 IN	8 IN SCH 80 HDPE

#### REVISIONS REVISIONS DATE BY CHK APR DATE BY CHK APF 11/26/18 EA SA SA A ISSUED FOR REVIEW 12/19/18 JSS SRA SRA 02/22/19 JSS SRA SRA B ISSUED FOR REVIEW C ISSUED FOR REVIEW 06/03/19 JSS SRA SRA D ISSUED FOR REVIEW





### NOTES

- 1. CONTRACTOR SHALL CONTACT LOCAL ONE CALL UTILITY LOCATING SERVICES, PRIOR TO
- 2. REGARDING PAVED ROAD UNDERGROUND POWER CABLE CROSSINGS:
- 2.a. WHEN MV COLLECTION CIRCUITS CROSS UNDER PAVED ROADS, THESE CABLES SHALL BE INSTALLED IN CONDUIT VIA HORIZONTAL DIRECTIONAL BORING (HDB) UNDER THE ROADWAY.
- 2.b. A #4/O AWG BARE COPPER GROUND WIRE SHALL BE INSTALLED WITH EACH POWER CIRCUIT IN THE SAME CONDUIT.
- 2.c. THE CONTRACTOR SHALL OBTAIN ALL NECESSARY PERMITS BEFORE COMMENCING WORK. THE CONTRACTOR SHALL PREPARE DRAWINGS OR SKETCHED DETAILS OF THE CABLE CROSSING AS PART OF THE PERMIT APPLICATION. THE CONTRACTOR SHALL BE RESPONSIBLE FOR APPLYING FOR AND SECURING ANY AND ALL PERMITS AND PERMIT PAYMENTS AND/OR APPLICATION FEES.
- 2.d. THE CONTRACTOR SHALL OBTAIN APPROVAL OF THE OWNER OF ALL CROSSING CONSTRUCTION METHODS.
- 2.e. THE CONTRACTOR SHALL COMPLY WITH ANY SPECIFIC AGREEMENTS AND PERMITS OBTAINED FROM ROAD OWNER/OPERATOR. IN THE CASE THAT THIS DOCUMENT CONFLICTS WITH THESE SPECIFIC AGREEMENTS AND/OR PERMITS, THE CONTRACTOR SHALL COMPLY WITH THE AGREEMENTS/PERMITS AND NOTIFY THE ENGINEER OF RECORD OF THE CONFLICT.
- 2.f. THE CONTRACTOR MAY UTILIZE A SINGLE SPLICE ON ONE SIDE OF THE CROSSING. THE SPLICE MUST BE PLACE OUTSIDE OF THE RIGHT-OF-WAY, EASEMENT, OR ANY OTHER PROPERTY SETBACKS FOR FUTURE ACCESS.
- 2.g. THE CONTRACTOR SHALL MAINTAIN A MINIMUM DEPTH of 48-INCHES TO THE TOP OF CONDUIT AND BELOW THE LOWEST GRADE IN THE RIGHT-OF-WAY AT THE CROSSING LOCATION.
- 2.h. CABLES SHALL BE WRAP-TIED IN TREFOIL CONFIGURATION AT LEAST EVERY 10' THROUGHOUT THE ENTIRE BORE CONDUIT.
- 2.i. IN THE INTEREST OF SAFETY, THE FACE OF THE BORE PIT SHALL BE NO CLOSER THAN 15' TO THE BOTTOM OF THE ROADWAY EMBANKMENT (OR DITCH FLOW LINE) AND/OR NO CLOSER THAN 30' TO THE EDGE OF THE TRAVELED SURFACE, UNLESS OTHERWISE SPECIFIED OR DIRECTED BY THE STATE/LOCAL AUTHORITY REGULATIONS OR DISCRETION.
- 3. REGARDING UNPAVED OR GRAVEL ROAD CROSSINGS:
- 3.a. REFER TO DETAIL "F" ON MHS-E-520-01 FOR MORE INFORMATION ABOUT CUTTING TRENCHES THROUGH GRAVEL OR UNPAVED ROADS.
- 3.b. DISTURBED PORTIONS OF THE ROADWAY SHALL BE RESTORED TO ORIGINAL
- CONDITION AS DESCRIBED IN THE TRENCH DETAIL DRAWINGS. 3.c. CARE SHALL BE TAKEN NOT TO DAMAGE CABLE DURING COMPACTION OF GRAVEL.
- 4. PERMANENT ABOVE GROUND MARKERS IDENTIFYING UNDERGROUND CROSSING POWER CABLES SHALL BE INSTALLED AND MAINTAINED AT BOTH EDGES OF THE ROW EASEMENT.
- 5. IN THE INTEREST OF SAFETY, TRENCHING AND THE PARKING OF EQUIPMENT SHOULD BE PERFORMED AS FAR AS POSSIBLE FROM TRAFFIC LANES.
- 6. NO DIGGING OR EQUIPMENT WILL BE PERMITTED IN CENTER MEDIANS OR DITCH LINES OR ROAD R.O.W. WITHOUT WRITTEN PERMISSION FROM THE EASEMENT OWNER. SPECIAL NOTE:
- REFER TO 17 CRR-NY131.9 DEPTH OF BURY AND VERTICAL AND LATERAL CLEARANCES, AND 17 CRR-NY131.19 UNDERGROUND WORK.

## CONCEPTUAL - NOT FOR CONSTRUCTION


DWG.NO. MHS-E-522-01

SHEET 1 OF 4


ENGINEERING RECORD	DATE	
DRAWN: J. STRUBLE	02/15/19	MOHAWK SOLAR
DESIGNED: J. STRUBLE	02/15/19	34.5KV COLLECTION SYSTE
CHECKED: S.AKERS	06/03/19	ROAD CROSSING DETAILS
APPROVED: S.AKERS	06/03/19	

SCALE:NTS

CADFILE: MHS-E-522-01.DWG




ROAD CROSSING 1 - PLAN VIEW



**ROAD CROSSING 3 - PLAN VIEW** 



ROAD CROSSING 2 - PLAN VIEW



ROAD CROSSING 4 - PLAN VIEW

#### REVISIONS REVISIONS DATE 11/26/18 EA SA SA 12/19/18 JSS SRA SRA 02/22/19 JSS SRA SRA 06/03/19 JSS SRA SRA A ISSUED FOR REVIEW B ISSUED FOR REVIEW ISSUED FOR REVIEW D ISSUED FOR REVIEW





1. CONTRACTOR SHALL CONTACT LOCAL ONE CALL UTILITY LOCATING SERVICES, PRIOR TO

NOTES

- REGARDING PAVED ROAD UNDERGROUND POWER CABLE CROSSINGS:
- 2.a. WHEN MV COLLECTION CIRCUITS CROSS UNDER PAVED ROADS, THESE CABLES SHALL BE INSTALLED IN CONDUIT VIA HORIZONTAL DIRECTIONAL BORING (HDB)
- 2.b. A #4/0 AWG BARE COPPER GROUND WIRE SHALL BE INSTALLED WITH EACH POWER CIRCUIT IN THE SAME CONDUIT.
- 2.c. THE CONTRACTOR SHALL OBTAIN ALL NECESSARY PERMITS BEFORE COMMENCING WORK. THE CONTRACTOR SHALL PREPARE DRAWINGS OR SKETCHED DETAILS OF THE CABLE CROSSING AS PART OF THE PERMIT APPLICATION. THE CONTRACTOR SHALL BE RESPONSIBLE FOR APPLYING FOR AND SECURING ANY AND ALL PERMITS AND PERMIT PAYMENTS AND/OR APPLICATION FEES.
- 2.d. THE CONTRACTOR SHALL OBTAIN APPROVAL OF THE OWNER OF ALL CROSSING CONSTRUCTION METHODS.
- 2.e. THE CONTRACTOR SHALL COMPLY WITH ANY SPECIFIC AGREEMENTS AND PERMITS OBTAINED FROM ROAD OWNER/OPERATOR. IN THE CASE THAT THIS DOCUMENT CONFLICTS WITH THESE SPECIFIC AGREEMENTS AND/OR PERMITS, THE CONTRACTOR SHALL COMPLY WITH THE AGREEMENTS/PERMITS AND NOTIFY THE ENGINEER OF RECORD OF THE CONFLICT.
- 2.f. THE CONTRACTOR MAY UTILIZE A SINGLE SPLICE ON ONE SIDE OF THE CROSSING. THE SPLICE MUST BE PLACE OUTSIDE OF THE RIGHT-OF-WAY, EASEMENT, OR ANY OTHER PROPERTY SETBACKS FOR FUTURE ACCESS.
- 2.g. THE CONTRACTOR SHALL MAINTAIN A MINIMUM DEPTH of 48-INCHES TO THE TOP OF CONDUIT AND BELOW THE LOWEST GRADE IN THE RIGHT-OF-WAY AT THE CROSSING LOCATION.
- CABLES SHALL BE WRAP-TIED IN TREFOIL CONFIGURATION AT LEAST EVERY 10' THROUGHOUT THE ENTIRE BORE CONDUIT.
- 2.i. IN THE INTEREST OF SAFETY, THE FACE OF THE BORE PIT SHALL BE NO CLOSER THAN 15' TO THE BOTTOM OF THE ROADWAY EMBANKMENT (OR DITCH FLOW LINE) AND/OR NO CLOSER THAN 30' TO THE EDGE OF THE TRAVELED SURFACE, UNLESS OTHERWISE SPECIFIED OR DIRECTED BY THE STATE/LOCAL AUTHORITY REGULATIONS OR DISCRETION.
- 3. REGARDING UNPAVED OR GRAVEL ROAD CROSSINGS:
- 3.a. REFER TO DETAIL "F" ON MHK-E-520-01 FOR MORE INFORMATION ABOUT CUTTING TRENCHES THROUGH GRAVEL OR UNPAVED ROADS.
- 3.b. DISTURBED PORTIONS OF THE ROADWAY SHALL BE RESTORED TO ORIGINAL
- CONDITION AS DESCRIBED IN THE TRENCH DETAIL DRAWINGS. 3.c. CARE SHALL BE TAKEN NOT TO DAMAGE CABLE DURING COMPACTION OF GRAVEL.
- 4. PERMANENT ABOVE GROUND MARKERS IDENTIFYING UNDERGROUND CROSSING POWER CABLES SHALL BE INSTALLED AND MAINTAINED AT BOTH EDGES OF THE ROW EASEMENT.
- 5. IN THE INTEREST OF SAFETY, TRENCHING AND THE PARKING OF EQUIPMENT SHOULD BE PERFORMED AS FAR AS POSSIBLE FROM TRAFFIC LANES.
- 6. NO DIGGING OR EQUIPMENT WILL BE PERMITTED IN CENTER MEDIANS OR DITCH LINES OR ROAD R.O.W. WITHOUT WRITTEN PERMISSION FROM THE EASEMENT OWNER.

REFER TO 17 CRR-NY131.9 DEPTH OF BURY AND VERTICAL AND LATERAL CLEARANCES,


AND 17 CRR-NY131.19 UNDERGROUND WORK.

## CONCEPTUAL - NOT FOR CONSTRUCTION

EERING RECORD	DATE	
J. STRUBLE	02/15/19	MOHAWK SOLAR
ED: J. STRUBLE	02/15/19	34.5KV COLLECTION SY
D: S.AKERS	06/03/19	ROAD CROSSING DETA
/ED: S.AKERS	06/03/19	

YSTEM

DWG.NO. MHS-E-522-01 SHEET 2 OF 4







7 ROAD CROSSING 7 - PLAN VIEW



ROAD CROSSING 6 - PLAN VIEW



8 ROAD CROSSING 8 - PLAN VIEW

## NO. REVISIONS DATE BY CHK APR NO. REVISIONS DATE BY CHK APR Image: Control of the problem of the problem





### NOTES

- I. CONTRACTOR SHALL CONTACT LOCAL ONE CALL UTILITY LOCATING SERVICES, PRIOR TO
- 2. REGARDING PAVED ROAD UNDERGROUND POWER CABLE CROSSINGS:
- 2.a. WHEN MV COLLECTION CIRCUITS CROSS UNDER PAVED ROADS, THESE CABLES SHALL BE INSTALLED IN CONDUIT VIA HORIZONTAL DIRECTIONAL BORING (HDB) UNDER THE ROADWAY.
- 2.b. A #4/O AWG BARE COPPER GROUND WIRE SHALL BE INSTALLED WITH EACH POWER CIRCUIT IN THE SAME CONDUIT.
- 2.c. THE CONTRACTOR SHALL OBTAIN ALL NECESSARY PERMITS BEFORE COMMENCING WORK. THE CONTRACTOR SHALL PREPARE DRAWINGS OR SKETCHED DETAILS OF THE CABLE CROSSING AS PART OF THE PERMIT APPLICATION. THE CONTRACTOR SHALL BE RESPONSIBLE FOR APPLYING FOR AND SECURING ANY AND ALL PERMITS AND PERMIT PAYMENTS AND/OR APPLICATION FEES.
- 2.d. THE CONTRACTOR SHALL OBTAIN APPROVAL OF THE OWNER OF ALL CROSSING CONSTRUCTION METHODS.
- 2.e. THE CONTRACTOR SHALL COMPLY WITH ANY SPECIFIC AGREEMENTS AND PERMITS OBTAINED FROM ROAD OWNER/OPERATOR. IN THE CASE THAT THIS DOCUMENT CONFLICTS WITH THESE SPECIFIC AGREEMENTS AND/OR PERMITS, THE CONTRACTOR SHALL COMPLY WITH THE AGREEMENTS/PERMITS AND NOTIFY THE ENGINEER OF RECORD OF THE CONFLICT.
- 2.f. THE CONTRACTOR MAY UTILIZE A SINGLE SPLICE ON ONE SIDE OF THE CROSSING.
  THE SPLICE MUST BE PLACE OUTSIDE OF THE RIGHT—OF—WAY, EASEMENT, OR ANY
  OTHER PROPERTY SETBACKS FOR FUTURE ACCESS.
- 2.g. THE CONTRACTOR SHALL MAINTAIN A MINIMUM DEPTH of 48—INCHES TO THE TOP OF CONDUIT AND BELOW THE LOWEST GRADE IN THE RIGHT—OF—WAY AT THE CROSSING LOCATION.
- 2.h. CABLES SHALL BE WRAP-TIED IN TREFOIL CONFIGURATION AT LEAST EVERY 10' THROUGHOUT THE ENTIRE BORE CONDUIT.
- 2.i. IN THE INTEREST OF SAFETY, THE FACE OF THE BORE PIT SHALL BE NO CLOSER THAN 15' TO THE BOTTOM OF THE ROADWAY EMBANKMENT (OR DITCH FLOW LINE) AND/OR NO CLOSER THAN 30' TO THE EDGE OF THE TRAVELED SURFACE, UNLESS OTHERWISE SPECIFIED OR DIRECTED BY THE STATE/LOCAL AUTHORITY REGULATIONS OR DISCRETION.
- 3. REGARDING UNPAVED OR GRAVEL ROAD CROSSINGS:
- 3.a. REFER TO DETAIL "F" ON MHK—E—520—01 FOR MORE INFORMATION ABOUT CUTTING TRENCHES THROUGH GRAVEL OR UNPAVED ROADS.
- 3.b. DISTURBED PORTIONS OF THE ROADWAY SHALL BE RESTORED TO ORIGINAL CONDITION AS DESCRIBED IN THE TRENCH DETAIL DRAWINGS.
- CONDITION AS DESCRIBED IN THE TRENCH DETAIL DRAWINGS.

  3.c. CARE SHALL BE TAKEN NOT TO DAMAGE CABLE DURING COMPACTION OF GRAVEL.
- 4. PERMANENT ABOVE GROUND MARKERS IDENTIFYING UNDERGROUND CROSSING POWER CABLES SHALL BE INSTALLED AND MAINTAINED AT BOTH EDGES OF THE ROW EASEMENT.
- 5. IN THE INTEREST OF SAFETY, TRENCHING AND THE PARKING OF EQUIPMENT SHOULD BE PERFORMED AS FAR AS POSSIBLE FROM TRAFFIC LANES.
- 6. NO DIGGING OR EQUIPMENT WILL BE PERMITTED IN CENTER MEDIANS OR DITCH LINES OR ROAD R.O.W. WITHOUT WRITTEN PERMISSION FROM THE EASEMENT OWNER.

REFER TO 17 CRR-NY131.9 DEPTH OF BURY AND VERTICAL AND LATERAL CLEARANCES, AND 17 CRR-NY131.19 UNDERGROUND WORK.

CONCEPTUAL - NOT FOR CONSTRUCTION

NGINEERING RECORD	DATE	
RAWN: J. STRUBLE	02/15/19	
ESIGNED: J. STRUBLE	02/15/19	34.
HECKED: S.AKERS	06/03/19	R
PPROVED: S.AKERS	06/03/19	1 \

APPROVED: S.AKERS 06/03/19 CADFILE: MHS-E-522-01.DWG SCALE:NTS DWG.NO. **MHS-E-522-01** SHEET 3 OF 4 REV D



ROAD CROSSING 9 - PLAN VIEW

#### REVISIONS DATE BY CHK APR REVISIONS DATE BY CHK APF 11/26/18 EA SA SA A ISSUED FOR REVIEW 12/19/18 JSS SRA SRA 02/22/19 JSS SRA SRA B ISSUED FOR REVIEW C ISSUED FOR REVIEW D ISSUED FOR REVIEW 06/03/19 JSS SRA SRA





#### CONCEPTUAL - NOT FOR CONSTRUCTION ENGINEERING RECORD | DATE DRAWN: J. STRUBLE 02/15/19 DESIGNED: J. STRUBLE 02/15/19 CHECKED: S.AKERS 06/03/19 06/03/1 APPROVED: S.AKERS CADFILE: MHS-E-522-01.DWG

MOHAWK SOLAR 34.5KV COLLECTION SYSTEM ROAD CROSSING DETAILS

SHEET 4 OF 4

DWG.NO. MHS-E-522-01

1. CONTRACTOR SHALL CONTACT LOCAL ONE CALL UTILITY LOCATING SERVICES, PRIOR TO 2. REGARDING PAVED ROAD UNDERGROUND POWER CABLE CROSSINGS:

2.a. WHEN MV COLLECTION CIRCUITS CROSS UNDER PAVED ROADS, THESE CABLES

NOTES

SHALL BE INSTALLED IN CONDUIT VIA HORIZONTAL DIRECTIONAL BORING (HDB) UNDER THE ROADWAY.

2.b. A #4/O AWG BARE COPPER GROUND WIRE SHALL BE INSTALLED WITH EACH POWER CIRCUIT IN THE SAME CONDUIT.

2.c. THE CONTRACTOR SHALL OBTAIN ALL NECESSARY PERMITS BEFORE COMMENCING WORK. THE CONTRACTOR SHALL PREPARE DRAWINGS OR SKETCHED DETAILS OF THE CABLE CROSSING AS PART OF THE PERMIT APPLICATION. THE CONTRACTOR SHALL BE RESPONSIBLE FOR APPLYING FOR AND SECURING ANY AND ALL PERMITS AND PERMIT PAYMENTS AND/OR APPLICATION FEES.

2.d. THE CONTRACTOR SHALL OBTAIN APPROVAL OF THE OWNER OF ALL CROSSING

CONSTRUCTION METHODS.

2.e. THE CONTRACTOR SHALL COMPLY WITH ANY SPECIFIC AGREEMENTS AND PERMITS OBTAINED FROM ROAD OWNER/OPERATOR. IN THE CASE THAT THIS DOCUMENT CONFLICTS WITH THESE SPECIFIC AGREEMENTS AND/OR PERMITS, THE CONTRACTOR SHALL COMPLY WITH THE AGREEMENTS/PERMITS AND NOTIFY THE ENGINEER OF RECORD OF THE CONFLICT.

2.f. THE CONTRACTOR MAY UTILIZE A SINGLE SPLICE ON ONE SIDE OF THE CROSSING. THE SPLICE MUST BE PLACE OUTSIDE OF THE RIGHT-OF-WAY, EASEMENT, OR ANY OTHER PROPERTY SETBACKS FOR FUTURE ACCESS.

2.g. THE CONTRACTOR SHALL MAINTAIN A MINIMUM DEPTH of 48-INCHES TO THE TOP OF CONDUIT AND BELOW THE LOWEST GRADE IN THE RIGHT-OF-WAY AT THE CROSSING LOCATION.

2.h. CABLES SHALL BE WRAP-TIED IN TREFOIL CONFIGURATION AT LEAST EVERY 10' THROUGHOUT THE ENTIRE BORE CONDUIT.

2.i. IN THE INTEREST OF SAFETY, THE FACE OF THE BORE PIT SHALL BE NO CLOSER THAN 15' TO THE BOTTOM OF THE ROADWAY EMBANKMENT (OR DITCH FLOW LINE) AND/OR NO CLOSER THAN 30' TO THE EDGE OF THE TRAVELED SURFACE, UNLESS OTHERWISE SPECIFIED OR DIRECTED BY THE STATE/LOCAL AUTHORITY REGULATIONS OR DISCRETION.

3. REGARDING UNPAVED OR GRAVEL ROAD CROSSINGS:

3.a. REFER TO DETAIL "F" ON MHK-E-520-01 FOR MORE INFORMATION ABOUT CUTTING TRENCHES THROUGH GRAVEL OR UNPAVED ROADS.

3.b. DISTURBED PORTIONS OF THE ROADWAY SHALL BE RESTORED TO ORIGINAL


CONDITION AS DESCRIBED IN THE TRENCH DETAIL DRAWINGS. 3.c. CARE SHALL BE TAKEN NOT TO DAMAGE CABLE DURING COMPACTION OF GRAVEL.

4. PERMANENT ABOVE GROUND MARKERS IDENTIFYING UNDERGROUND CROSSING POWER CABLES SHALL BE INSTALLED AND MAINTAINED AT BOTH EDGES OF THE ROW EASEMENT.

5. IN THE INTEREST OF SAFETY, TRENCHING AND THE PARKING OF EQUIPMENT SHOULD BE PERFORMED AS FAR AS POSSIBLE FROM TRAFFIC LANES.

6. NO DIGGING OR EQUIPMENT WILL BE PERMITTED IN CENTER MEDIANS OR DITCH LINES OR ROAD R.O.W. WITHOUT WRITTEN PERMISSION FROM THE EASEMENT OWNER. SPECIAL NOTE:

REFER TO 17 CRR-NY131.9 DEPTH OF BURY AND VERTICAL AND LATERAL CLEARANCES, AND 17 CRR-NY131.19 UNDERGROUND WORK.



THO TELL THE EIGH OF BOILED THILE THEELIMINGT THE CODDLETT TO OTHER		NOTE: THE	LIST	OF	BORES	ARE	PRELIMINARY	AND	SUBJECT	ТО	CHANGE
---	--	-----------	------	----	-------	-----	-------------	-----	---------	----	--------

NO.	REVISIONS	DATE	BY	CHK	APR	NO.	REVISIONS	DATE	BY	СНК	APR
						Α	ISSUED FOR REVIEW	11/26/18	EA	SA	SA
						В	ISSUED FOR REVIEW	12/19/18	JSS	SRA	SRA
						С	ISSUED FOR REVIEW	02/22/19	JSS	SRA	SRA
						D	ISSUED FOR REVIEW	06/03/19	JSS	SRA	SRA






#### CONCEPTUAL - NOT FOR CONSTRUCT ENGINEERING RECORD DATE MOHAWK SOLAR DRAWN: J. STRUBLE 02/15/19 DESIGNED: J. STRUBLE 02/15/19


06/03/1 DWG.NO. **MHS-E-522-02** SHEET 1 OF 3 CADFILE: MHS-E-522-02.DWG

34.5KV COLLECTION SYSTEM 06/03/19 PIPELINE/T-LINE ROW CROSSING DETAILS CHECKED: S.AKERS APPROVED: S.AKERS

NOTES









3 PIPELINE CROSSING 3 - PLAN VIEW

DATE

REVISIONS



PIPELINE CROSSING 2 - PLAN VIEW



4 PIPELINE CROSSING 4 - PLAN VIEW

# NO. REVISIONS DATE BY CHK APR 11/26/18 EA SA SA B ISSUED FOR REVIEW 12/19/18 JSS SRA SRA C ISSUED FOR REVIEW 02/22/19 JSS SRA SRA D ISSUED FOR REVIEW 06/03/19 JSS SRA SRA






## CONCEPTUAL - NOT FOR CONSTRUCTION

ENGINEERING RECORD	DATE				
DRAWN: J. STRUBLE	02/15/19		MOHAWK SOLA	.K	
DESIGNED: J. STRUBLE	02/15/19	34.5	5KV COLLECTION	SYSTEM	
CHECKED: S.AKERS	06/03/19	PIPE	ELINE CROSSING	DETAILS	
APPROVED: S.AKERS	06/03/19	_			
CADFILE: MHS-E-522-0	2.DWG	SCALE:NTS	DWG.NO. MHS-E-522-02	SHEET 2 OF 3	REV D

## NOTES

- 1. PRIOR TO EXCAVATION, CONTRACTOR SHALL CONTACT LOCAL ONE CALL UTILITY LOCATING SERVICES TO VERIFY DEPTH AND LOCATION OF ALL UTILITIES AT THE CROSSING LOCATION.
- 2. ALL PIPELINE CROSSINGS SHALL COMPLY WITH SPECIFIC AGREEMENTS AND PERMITS WITH PIPELINE OWNER/OPERATOR. IN THE CASE THAT THIS DOCUMENT CONFLICTS WITH THESE SPECIFIC AGREEMENTS AND/OR PERMITS, THE CONTRACTOR SHALL COMPLY WITH THE AGREEMENTS/PERMITS AND NOTIFY THE OWNER OF THE CONFLICT.
- 3. PERMANENT ABOVE GRADE ROUTE MARKERS SHALL BE INSTALLED AND MAINTAINED AT THE LIMITS OF THE PIPELINE EASEMENT UNLESS THE CROSSING IS IN A CULTIVATED FIELD. IF CROSSING IS IN A CULTIVATED FIELD, THEN UNDERGROUND EXTENDED—RANGE MARKER BALLS SHALL BE INSTALLED.
- 4. EACH INSTALLED CROSSING SHALL BE ENCASED THROUGHOUT THE WIDTH OF THE PIPELINE UTILITY EASEMENT.
- 5. CONTRACTOR SHALL PROVIDE AND INSTALL A PLASTIC WARNING TAPE 18 INCHES BELOW GRADE.
- 6. CONTRACTOR SHALL MAINTAIN A SEPARATION OF NOT LESS THAN 24 INCHES WHEN PARALLELING GAS, WATER, OIL, OR OTHER PIPELINE SYSTEMS AND NOT LESS THAN 24 INCHES WHEN CROSSING THESE PIPELINE SYSTEMS BETWEEN THE BOTTOM OF THE PIPELINE SYSTEM AND THE TOP OF THE COLLECTION SYSTEM INSTALLATION CONDUIT, UNLESS OTHERWISE SPECIFICALLY AGREED UPON AND NOTED BY AVANGRID AND THE PIPELINE UTILITY PRIOR TO CONSTRUCTION.
- 7. COLLECTION SYSTEM CABLES SHALL BE SEPARATED FROM GAS TRANSMISSION LINES BY A CLEARANCE OF NOT LESS THAN 24 INCHES. IF THIS CLEARANCE CANNOT BE ATTAINED, THE GAS TRANSMISSION LINE SHALL BE PROTECTED FROM DAMAGE THAT MIGHT RESULT FROM THE PROXIMITY OF THE COLLECTION SYSTEM CABLES.
- 8. A THREE PHASE SPLICE CAN BE INSTALLED ON EITHER SIDE OF THE CROSSING FOR PULLING THROUGH THE CONDUIT. ALL SPLICES TO BE APPROVED BY THE OWNER PRIOR TO INSTALLATION.



PIPELINE CROSSING 5 - PLAN VIEW

NO.	. REVISIONS	DATE	BY CHK	APR	NO.	REVISIONS	DATE	BY	CHK	APF
					Α	ISSUED FOR REVIEW	11/26/18		1	SA
						ISSUED FOR REVIEW	12/19/18		SRA	
					С	ISSUED FOR REVIEW			SRA	
					D	ISSUED FOR REVIEW	06/03/19	JSS	SRA	SRA





## ENGINEERING RECORD DATE DRAWN: J. STRUBLE 02/15/19 DESIGNED: J. STRUBLE 02/15/19 CHECKED: S.AKERS 06/03/19 APPROVED: S.AKERS 06/03/19

MOHAWK SOLAR 34.5KV COLLECTION SYSTEM PIPELINE CROSSING DETAILS

NOTES

PRIOR TO EXCAVATION, CONTRACTOR SHALL CONTACT LOCAL ONE CALL UTILITY LOCATING SERVICES TO VERIFY DEPTH AND LOCATION OF ALL UTILITIES AT THE

2. ALL PIPELINE CROSSINGS SHALL COMPLY WITH SPECIFIC AGREEMENTS AND PERMITS

THE AGREEMENTS/PERMITS AND NOTIFY THE OWNER OF THE CONFLICT.

WITH PIPELINE OWNER/OPERATOR. IN THE CASE THAT THIS DOCUMENT CONFLICTS WITH THESE SPECIFIC AGREEMENTS AND/OR PERMITS, THE CONTRACTOR SHALL COMPLY WITH

3. PERMANENT ABOVE GRADE ROUTE MARKERS SHALL BE INSTALLED AND MAINTAINED AT THE LIMITS OF THE PIPELINE EASEMENT UNLESS THE CROSSING IS IN A CULTIVATED FIELD. IF CROSSING IS IN A CULTIVATED FIELD, THEN UNDERGROUND EXTENDED—RANGE

4. EACH INSTALLED CROSSING SHALL BE ENCASED THROUGHOUT THE WIDTH OF THE

5. CONTRACTOR SHALL PROVIDE AND INSTALL A PLASTIC WARNING TAPE 18 INCHES

6. CONTRACTOR SHALL MAINTAIN A SEPARATION OF NOT LESS THAN 24 INCHES WHEN

PARALLELING GAS, WATER, OIL, OR OTHER PIPELINE SYSTEMS AND NOT LESS THAN 24 INCHES WHEN CROSSING THESE PIPELINE SYSTEMS BETWEEN THE BOTTOM OF THE PIPELINE SYSTEM AND THE TOP OF THE COLLECTION SYSTEM INSTALLATION CONDUIT, UNLESS OTHERWISE SPECIFICALLY AGREED UPON AND NOTED BY AVANGRID AND THE

7. COLLECTION SYSTEM CABLES SHALL BE SEPARATED FROM GAS TRANSMISSION LINES BY

ATTAINED, THE GAS TRANSMISSION LINE SHALL BE PROTECTED FROM DAMAGE THAT

PULLING THROUGH THE CONDUIT. ALL SPLICES TO BE APPROVED BY THE OWNER PRIOR

A CLEARANCE OF NOT LESS THAN 24 INCHES. IF THIS CLEARANCE CANNOT BE

8. A THREE PHASE SPLICE CAN BE INSTALLED ON EITHER SIDE OF THE CROSSING FOR

MIGHT RESULT FROM THE PROXIMITY OF THE COLLECTION SYSTEM CABLES.

CROSSING LOCATION.

MARKER BALLS SHALL BE INSTALLED.

PIPELINE UTILITY PRIOR TO CONSTRUCTION.

PIPELINE UTILITY EASEMENT.

BELOW GRADE.

TO INSTALLATION.

